

Fraunhofer-Institut für Bauphysik Postf. 80 04 69 70504 Stuttgart, Germany

Hakan Plastik Piping Systems  
Mr. Ali Karadeniz  
Member of Board, COO  
Hakan Plastik Boru ve Profil San.Tic.A.S.  
Istiklal Caddesi. Cerkezkoy Org. San. Bolgesi  
No.11 Cerkezkoy /Tekirdag 59500 Turkiye

Directors  
Univ.-Prof. Dr.-Ing. Gerd Hauser  
Univ.-Prof. Dr.-Ing. Klaus Sedlbauer

Nobelstrasse 12  
70569 Stuttgart, Germany

Phone +49 711 970-00  
Fax +49 711 970-3395  
info@ibp.fraunhofer.de  
www.ibp.fraunhofer.de

Dipl.-Ing. (FH) Joachim Mohr  
Direct Dial +49 711 970-3348  
joachim.mohr@ibp.fraunhofer.de

Your Ref.	Your message of	Our Ref.	Stuttgart,
		Mo/Wb	October 30, 2009


### Test results, waste water noise, EN 14366

Dear Mr. Karadeniz,

enclosed you will receive the test results of August 18 and 19, 2009. Detailed information about test set up, test object and measurement procedure you will find in the test reports P-BA 186/2009e and 187/2009e.

Best regards  
Fraunhofer-Institute of Building Physics

Responsible Test Engineer:

  
Dipl.-Ing. (FH) Joachim Mohr

Head of Laboratory:

  
Dr. rer. nat. L. Weber

Annex: Table 1 and 2



Institution for testing, supervision and certification, officially recognized by the building supervisory authority  
Test laboratories accredited by  
the DAP according to  
DIN EN ISO/IEC 17025:2005



DEUTSCHES  
AKKREDITIERUNGSSYSTEM  
PRÜFWESSEN GMBH

**DAP**




DAP-PL-3743.26 Bauakustik und Schallimmissionsschutz  
DAP-PL-3743.30 Feuchte/Mörtel/Strahlung/Emissionsschutz  
DAP-PL-3743.25 Feuerstätten/Abgasanlagen  
DAP-PL-3743.27 Wärme-Kennwerte

Executive Board of the Fraunhofer-Gesellschaft  
Univ.-Prof. Dr.-Ing. habil. Prof. e.h. mult. Dr. h.c. mult.  
Hans-Jörg Bullinger, President  
Prof. Dr. rer. nat. Ulrich Buller  
Dr. rer. pol. Alfred Gossner  
Prof. Dr. phil. Marion Schick

Fraunhofer-Gesellschaft zur Förderung  
der angewandten Forschung e.V., München

Cheques and transfers payable to:  
Deutsche Bank, München  
Account 752193300 BLZ 700 700 10  
IBAN DE86 7007 0010 0752 1933 00,  
BIC (SWIFT-Code) DEUTDEMM  
V.A.T. Ident No DE129515865  
Tax Number 143/215/20392

**Table 1** Hakan, measurements of August 18, 2009. Sound pressure levels measured in the installation test facility. Test object was the wastewater system "HAKAN SiLENTA Premium Highly Noise-Insulated" (manufacturer Hakan). The wastewater system consisted of straight plastic pipes and fittings, nominal width OD 110 and pipe clamps "Bismat 1000 SX100 SL125" (manufacturer BIS Walraven).




	Wastewater system "HAKAN SiLENTA Premium Highly Noise-Insulated" with pipe clamps "Bismat 1000 SX100 SL125"			
Flow rate [l/s]	0,5	1,0	2,0	4,0
Installation sound level $L_{in}$ [dB(A)] measured in the basement test-room UG front <sup>1)</sup>	43	45	48	50
Installation sound level $L_{in}$ [dB(A)] measured in the basement test-room UG rear <sup>1)</sup>	6	9	9	15
Airborne sound pressure level $L_{a,A}$ [dB(A)] <sup>2)</sup>	43	45	48	50
Structure-born sound characteristic level $L_{sc,A}$ [dB(A)] <sup>2)</sup>	4	7	7	13

<sup>1)</sup> Evaluation according to DIN 4109.

<sup>2)</sup> Evaluation according to DIN EN 14366.


**Table 2** Hakan, measurements of August 19, 2009. Sound pressure levels measured in the installation test facility. Test object was the wastewater system "HAKAN SiLENTA 3A Noise Insulated DIN4102" (manufacturer Hakan). The wastewater system consisted of straight plastic pipes and fittings, nominal width OD 110 and pipe clamps "Bismat 1000 SX100 SL125" (manufacturer BIS Walraven).



	Wastewater system "HAKAN SiLENTA 3A Noise Insulated DIN4102" with pipe clamps "Bismat 1000 SX100 SL125"			
Flow rate [l/s]	0,5	1,0	2,0	4,0
Installation sound level $L_{in}$ [dB(A)] measured in the basement test-room UG front <sup>1)</sup>	46	48	49	52
Installation sound level $L_{in}$ [dB(A)] measured in the basement test-room UG rear <sup>1)</sup>	9	10	12	19
Airborne sound pressure level $L_{a,A}$ [dB(A)] <sup>2)</sup>	46	48	49	52
Structure-born sound characteristic level $L_{sc,A}$ [dB(A)] <sup>2)</sup>	7	8	9	16


<sup>1)</sup> Evaluation according to DIN 4109.

<sup>2)</sup> Evaluation according to DIN EN 14366.




**Figure 1** Wastewater pipe system "HAKAN SiLENTA Premium Highly Noise-Insulated Pipes (OD 110)" (manufacturer: HAKAN) mounted in sub-basement (KG), basement (UG front), ground floor (EG front) and top floor (DG) using pipe clamps "Bismat 1000 (SX100/SL125)" made by Walraven. The installation sound level  $L_{in}$  was measured at various flow rates in the test rooms UG front (above) and UG rear (below).

The tests were performed in a laboratory accredited by the German Accreditation System for Testing (DAP, file no. PL-3743.26) according to standard EN ISO/IEC 17025.




**Figure 2** Wastewater pipe system "HAKAN SiLENTA Premium Highly Noise-Insulated Pipes (OD 110)" (manufacturer: HAKAN) mounted in sub-basement (KG), basement (UG front), ground floor (EG front) and top floor (DG) using pipe clamps "Bismat 1000 (SX100/SL125)" made by Walraven. Airborne sound pressure level (above) and structure-borne sound characteristic level (below) measured at various flow rates according to DIN EN 14366.

The tests were performed in a laboratory accredited by the German Accreditation System for Testing (DAP, file no. PL-3743.26) according to standard EN ISO/IEC 17025.




**Figure 3** Wall structural sensitivity level  $L_{SS}$  of the installation wall between the test rooms UG front and UG rear in the installation test facility in the Fraunhofer-Institute of Building Physics. The installation wall consists of lime stones (thickness 115 mm, ceiled on both sides) with a mass per unit area of 220 kg/m<sup>2</sup>. The indicated structural sensitivity level  $L_{SS}$  refers to the mounting position of the waste water system according to figure 4. For comparison the wall structural sensitivity level  $L_{SSR}$  of the reference wall is also indicated (evaluation according to DIN EN 14366).

The tests were performed in a laboratory accredited by the German Accreditation System for Testing (DAP, file no. PL-3743.26) according to standard EN ISO/IEC 17025.



**Figure 1** Wastewater pipe system "HAKAN 3A Low Noise Pipe (OD 110)" (manufacturer: HAKAN) mounted in sub-basement (KG), basement (UG front), ground floor (EG front) and top floor (DG) using pipe clamps "Bismat 1000 (SX100/SL125)" made by Walraven. The installation sound level  $L_{in}$  was measured at various flow rates in the test rooms UG front (above) and UG rear (below).


The tests were performed in a laboratory accredited by the German Accreditation System for Testing (DAP, file no. PL-3743.26) according to standard EN ISO/IEC 17025.



**Figure 2** Wastewater pipe system "HAKAN 3A Low Noise Pipe (OD 110) (manufacturer: HAKAN) mounted in sub-basement (KG), basement (UG front), ground floor (EG front) and top floor (DG) using pipe clamps "Bismat 1000 (SX100/SL125)" made by Walraven. Airborne sound pressure level (above) and structure-borne sound characteristic level (below) measured at various flow rates according to DIN EN 14366.


The tests were performed in a laboratory accredited by the German Accreditation System for Testing (DAP, file no. PL-3743.26) according to standard EN ISO/IEC 17025.






**Figure 3** Wall structural sensitivity level  $L_{SS}$  of the installation wall between the test rooms UG front and UG rear in the installation test facility in the Fraunhofer-Institute of Building Physics. The installation wall consists of lime stones (thickness 115 mm, ceiled on both sides) with a mass per unit area of 220 kg/m<sup>2</sup>. The indicated structural sensitivity level  $L_{SS}$  refers to the mounting position of the waste water system according to figure 4. For comparison the wall structural sensitivity level  $L_{SSR}$  of the reference wall is also indicated (evaluation according to DIN EN 14366).

The tests were performed in a laboratory accredited by the German Accreditation System for Testing (DAP, file no. PL-3743.26) according to standard EN ISO/IEC 17025.



**Figure 4** Installation plan of the pipe system "HAKAN SiLENTA Premium Highly Noise-Insulated Pipes (OD 110)" (manufacturer: HAKAN), mounted with clamps "Bismat 1000 (SX100/SL125)" (drawing not to scale, dimensions in mm).



**Figure 4** Installation plan of the pipe system "HAKAN 3A Low Noise Pipe (OD 110)" (manufacturer: HAKAN), mounted with clamps "Bismat 1000 (SX100/SL125)" (drawing not to scale, dimensions in mm).